

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7125-1501:110

Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 \*FAX (941) 308-81234

**DESIGN:** Models 2452THS-15-R, 2452THS-15-W, \*2452THS-75-R, \*2452THS-75-W, 2452THS-15/75-R, 2452THS-15/75-W, 2452THS-30-R, 2452THS-30-W, 2452THS-110-R and 2452THS-110-W horn/strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Horn: 20-24 VDC  
Strobe: 15cd, 30cd, \*75cd, 15/75cd, 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela ratings, and UL label.

**APPROVAL:** Listed as horn strobes for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired applications. Model series 2452THS-15 are for indoor use only. All other models are suitable for indoor and outdoor use. Refer to listee's Installation Instruction Manual for details.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal

**FORMERLY:** 7125-1591:189 and 7125-1388:214

**XL:** 7125-1657:189

\*Rev. 07-19-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*